

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
Ghosh Para Road, Badamtala, P.O. - Bengal Enamel, P.S.
- Noapara, Pin - 700122**

Memo No : IND/WB/FES/20172018/10841

DATE: 25/08/2018

From :
The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :
Bholananda National Vidyalaya
55&56 Barrack Road, Barrackpore Kolkata-700120.
North Barrackpore F.S., Barrackpore,
North 24 Parganas - 700120 .





Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under group Educational at the premises no.- 55&56 Barrack Road, Barrackpore Kolkata-700120., Barrackpore, North 24 Parganas - 700120

This is in reference to your Application No. IND/WB/FES/20172018/10841, dated 25/08/2018, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under group Educational at the premises no.- 55&56 Barrack Road, Barrackpore Kolkata-700120., Barrackpore, North 24 Parganas - 700120.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.



28/9/2022
TAMAL HALDER
Manager
Bholananda National Vidyalaya
Barrackpore, Kolkata-700120



28/9/2022
Principal
Bholananda National Vidyalaya
CBSE Affiliation No.-2430005
Barrackpore, Kolkata-700120

1. This Renewal of Fire Safety Certificate is being issued for occupancy of "BHOLANANDA NATIONAL VIDYALAYA" at 55 & 56 Barrack Road, Barrackpore, Kolkata – 700 120.
2. Driveway must be free of any type of obstruction for easy movement of Fire appliances. No parking will be allowed on the Driveway.
3. The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
5. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear them, particularly lines above false ceiling & ducts.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
10. A trained Fireman shall be maintained round the clock for safety of the building.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
.. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
13. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Periodical flashing of water in the Hose Reel Hose Pipe line shall be made to maintain the efficiency working performance of above mention system.
15. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention Maintenance register.
16. This Renewal of Fire Safety Certificate is valid for three year and has to be renewed every year from the date of issue of this letter.
17. Each year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services performance of all the life & Fire Safety arrangements and installations of the building.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by Tarun Kumar
Sinha
Date: 2018.08.25 19:03:08 IST


28/9/2022
TAMAL HALDER
Manager
Bholananda National Vidyalaya
Barrackpore, Kolkata-700120


28/9/2022
Principal
Bholananda National Vidyalaya
CBSE Affiliation No.-2430005
Barrackpore, Kolkata-700120

Application Acknowledgment

Dear Mr. Tamal Halder,

Thank you for using West Bengal e-District System.

Your application for Renewal of Fire Safety Certificate under Government of West Bengal has been successfully submitted.

Application Summary


AIN : 0125191221100536
Name of the Applicant : Mr. Tamal Halder
Date of the Application : 19/08/2022
Address : BHOLANANDA NATIONAL VIDYALAYA,
55 AND 56 BARRACK ROAD, BARRACKPORE,
Post Office: BARRACKPORE,
Police Station: Barrackpore,
North 24 Parganas ,
West Bengal, India
Pin Code: 700120


For any query please contact your nearest Kiosk operator or the following contact details:

Government Of West Bengal Office Of The Director General West Bengal Fire & Emergency Services 13D,
Mirza Ghalib Street, Kolkata - 16

Applicants have to submit physical documents in proper order at the intimated Offices of Divisional Fire Officer within 04(four) days, failing which systematically/automatically applications will be rejected.

Print Finish


TAMAL HALDER
Manager
Bholananda National Vidyalaya
Barrackpore, Kolkata-700120


Principal 28/9/2022
Bholananda National Vidyalaya
CBSE Affiliation No.-2430005
Barrackpore, Kolkata-700120